

**GVYI.R14639****Gasketing and Edge-sealing Materials for Fire Doors, Positive-pressure Tested**[Page Bottom](#)**Gasketing and Edge-sealing Materials for Fire Doors, Positive-pressure Tested**[See General Information for Gasketing and Edge-sealing Materials for Fire Doors, Positive-pressure Tested](#)**COLUMBIA ALUMINUM PRODUCTS INC**

R14639

2565 Sampson Ave  
Corona, CA 92879 USA

Gasketing materials, Models:

Threshold Type: 161, 163, 164, 165, 166, 262, 263, 240, 241, 243, 270, 272, 273, 319, 255, 419, 661, 222, 223, 224, 225, 226, 210, 277, 493, 275, 494, 276, 278, 279, 490, 491, 283, 280, 281, 282, 476, 477, 492, "443", 482, 483, 484, 488, 495, 649, 654, 653, 682, 687, 688, 695, 698, 650, 694, 699, 651, 696, 652, 697, 480, 485, 486, 487, 489, 680, 681, 433, 439. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Threshold Type: 690, 691, 692, 693, 801, 802, 803, 804, 806, 807, 808, 809, 900, 900F, 901, 901F, 901SR, 901DSR, 902, 902SR, 902DSR 904, 905, 905F, 906, 907, 908, 909, 909HP, 910, 912HP, 912HP w/442 OS EXT, 925, 926, 931, 935, 942, 945, 950, 950F, 951, 951F, 952, 954, 955, 955F, 956, 958, 959, 959HP, 962HP, 969, 980, 981, 982, 983, 985, 988. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 20 minutes; wood and plastic covered composite doors rated up to 20 minutes; and wood core doors rated for 20 minutes.

Door Bottom Types: 244, 258, 258DV, 259, 259DV, 260, 260DV, 268, 268DV, 269, 269DV, 271, 271DV, 288, 668DV, 668, 669DV, 669, 667, 667DV, 675, 676, 677, 8393, 8551. Category J door bottoms are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs.

Threshold and Door Bottom Sets: 252, 253, 264, 265, 266, and 267. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Outswing Threshold Types: 245, 246, 248, 249, 298, 303, 309, 579, 580, 646, 663, 249. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Inswing Threshold Types: 248N, 249N, 620, 622, 623, 624, 305, 336, 339, 299, 307, 310, 311, 313, 413, 205, 206, 2090. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Door Weatherstrip Types: 320, 320F, 321, 321F, 324, 332, 334, 334S, 334STP, 334F. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Door Gasketing Type: 3338, 3339 brown or white, 3339S, 3338S, 3809, 334, 660. Category H smoke and draft control gaskets are intended for application to/with Classified hollow metal and steel covered composite type fire doors rated up to and including 3 hrs. and wood and plastic covered composite and wood core fire doors rated up to and including 1-1/2 hrs. When applied to the door and frame assembly in accordance with this manufacturer's installation instructions, the assembly will comply with NFPA 105.

Astragals: 340, 341, 338, 342, 342BV, 344, 344BV, 345, 347Q, 347BV, 348Q, 348BV, 348OS, 353, 346, 572, 573, 334, 660. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Door sweep: 335, 335N, 261, 250, 301, 674, 658, 657, 656, 300, 331, 660, 286, 288, 584, 586. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Automatic door bottom - 330, 302, 304, 336. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Miscellaneous: 256, 257, 287, 588. Category J gaskets for use with Listed steel frames and/or Classified steel covered composite, hollow metal doors rated up to 3 hrs; wood and plastic covered composite doors rated up to 1-1/2 hrs; and wood core doors rated for 20 minutes.

Model number may include an additional digit which designates finish; may be any number (0-3 and 5-9).

[Last Updated](#) on 2015-03-05[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".